

West Virginia's Public Record on Underground Storage Tanks

General Information:

Posted 03-01-2010

Total Number of UST Facilities: 2110
Total Number of Underground Storage Tanks (USTs): 5589

Summary Information For On-Site Inspections

Number Of UST Facilities Inspected: 769
Inspection Period Dates: 10/1/2008 to 9/30/2009
Percent Compliance (Combined Measure) 54%

Summary Information for Releases

Number of Confirmed UST Releases 82
Release Reporting Period Dates 10/1/2008 to 9/30/2009

Note: Tank, facility and on-site inspection information is based on undergrounds storage tanks regulated under Chapter 22 Article 17 of the West Virginia Code. On-site inspections measure compliance with release detection and release prevention measures of the significant operational compliance requirements described in EPA's September 30, 2003 Memorandum. Sources of release may total more than the number of confirmed releases due to some sites having multiple sources of releases. Specific information on underground storage tank release prevention is available through WVDEP's Office of Environmental Enforcement/UST Unit at 304-926-0470. Specific information on releases from underground storage tanks is available through WVDEP's Office of Environmental Remediation at 304-924-6211.

Summary Information For Release Sources and Causes

Source			Cause													
			Spill		Overfill		Phys/Mech Damage		Corrosion		Install Problem		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	17	18.5	0	0	0	0	3	17.6	14	82.4	0	0	0	0	0	0
Piping	19	20.6	0	0	0	0	9	47.5	8	42.1	1	5.2	0	0	1	5.2
Dispenser	28	30.4	0	0	0	0	27	96.5	0	0	0	0	1	3.5	0	0
STP	2	2.2	0	0	0	0	1	50	0	0	1	50	0	0	0	0
Delivery Problem	16	17.4	12	75	4	25	0	0	0	0	0	0	0	0	0	0
Other	2	2.2	0	0	0	0	0	0	2	100	0	0	0	0	0	0
Unknown	8	8.7	0	0	0	0	0	0	0	0	0	0	0	0	8	100
Totals	92	100	12	13	4	4.3	40	43.5	24	26.1	2	2.2	1	1.1	9	9.8